



# Additional reaction to fire classification report Nr 13854A

Owner of the classification report

BN INTERNATIONAL B.V.
Rokerijweg 5
NL-1271 AH HUIZEN
THE NETHERLANDS

### Introduction

This classification report defines the classification assigned to the product '**Digifort P300**' in accordance with the procedures given in the standard EN 13501-1: 2007: Fire classification of construction products and building elements - Part 1: classification using data from reaction to fire tests.

This classification report consists of 5 pages









### 1. <u>DETAILS OF CLASSIFIED PRODUCT</u>

### a) Nature and end use application

The product "Digifort P300" is defined as a 'decorative wall covering'. Its classification is valid for the following end use application(s): 'Used for attaching onto walls or ceilings, by means of an adhesive'

# b) Description

The product "Digifort P300" consists of a vinyl based wall covering with a paper backing. The weight of the vinyl layer (PVC) is 210 g/m². The weight of the paper backing is 90g/m².

	Nominal value
Mass per unit area (g/m²)	300

Mounting: The product was glued onto a calcium silicate board (12,5mm, 870 kg/m³) with BK10-PVA adhesive (200g/m²).

# 2. TEST REPORTS AND TEST RESULTS IN SUPPORT OF THIS CLASSIFICATION

### a) Test reports

Name of the laboratory	Name of the sponsor	Test report ref. Nr.	Test method
WFRGENT N.V.	BN International B.V.	9634, 12700D,	EN 13823
Ghent, Belgium	DIV IIILEITIALIOITAI D.V.	12700E	(February 2002)
WFRGENT N.V.	BN International B.V.	12700A, 12700B,	EN ISO 11925-2
Ghent, Belgium	DIV IIIteriiational B.V.	12700C	(February 2002)
WFRGENT N.V.	BN International B.V.	12700G	EXAP according to
Ghent, Belgium	DIN IIILEITIALIONAI D.V.	12700G	CEN/TS 15117

# Additional classification report Nr 13854A Page 3 of 5



### b) Test results

The second	Darameter		Results		0.11	
Test method		Number of tests	Continuous parameters Mean	Compliance parameters	Criteria for Class B-s2,d0  Continuous Compliand parameters paramete	
EN ISO 11925-2 (*) (1)						
30s flame application:						
Surface exposure	F <sub>s</sub> ≤ 150mm	6	(-)	Yes	(-)	Yes
- front side	Ignition filter paper		(-)	No	(-)	No
Edge exposure						
- front side	F <sub>s</sub> ≤ 150mm	6	(-)	Yes	(-)	Yes
	Ignition filter paper		(-)	No	(-)	No
EN 13823 (2)	FIGRA <sub>0,2 MJ</sub> (W/s)		95	(-)	≤ 120	(-)
	FIGRA <sub>0,4 MJ</sub> (W/s)		(-)	(-)	(-)	(-)
	LFS <sub><edge< sub=""></edge<></sub>		(-)	Yes	(-)	Yes
	THR <sub>600s</sub> (MJ)		1,5	(-)	≤ 7,5	(-)
	SMOGRA (m²/s²)	3	18	(-)	≤ 180	(-)
	TSP <sub>600s</sub> (m²) Flaming droplets/particles	3	67	(-)	≤ 200	(-)
	f<10s		(-)	Yes	(-)	Yes
	f>10s		(-)	No	(-)	No
EN ISO 11925-2 (*) (3) 30s flame application:						
Surface exposure	F <sub>s</sub> ≤ 150mm	6	(-)	Yes	(-)	Yes
- front side	Ignition filter paper		(-)	No	(-)	No
Edge exposure						
- front side	F <sub>s</sub> ≤ 150mm	6	(-)	Yes	(-)	Yes
7	Ignition filter paper		(-)	No	(-)	No
EN 13823 (4)	FIGRA <sub>0,2 MJ</sub> (W/s)		18	(-)	≤ 120	(-)
	FIGRA <sub>0,4 MJ</sub> (W/s)		(-)	(-)	(-)	(-)
	LFS <sub><edge< sub=""></edge<></sub>		(-)	Yes	(-)	Yes
	THR <sub>600s</sub> (MJ)		1,8	(-)	≤ 7,5	(-)
	SMOGRA (m²/s²)	3	7	(-)	≤ 180	(-)
	TSP <sub>600s</sub> (m <sup>2</sup> )	3	55	(-)	≤ 200	(-)
	Flaming					
	droplets/particles					
, I	f<10s		(-)	Yes	(-)	Yes
	f>10s		(-)	No	(-)	No

- (-) Not applicable
- (\*) The material did not melt nor pull away from the pilot burner.
- (1) Based on the results obtained in test report Nr. 12700A, "Digifort P300" white, design 2013
- (2) Based on the results obtained in test report Nr. 9634, "Digifort P300" white, design 2013
- (3) Based on the results obtained in test report Nr. 12700B, "Digifort P300" black, design 2193
- (4) Based on the results obtained in test report Nr. 12700D, "Digifort P300" black, design 2193

# Additional classification report Nr 13854A Page 4 of 5



EN ISO 11925-2 (*) (5) 30s flame application:						
Edge exposure						
- front side	F <sub>s</sub> ≤ 150mm	6	(-)	Yes	(-)	Yes
	Ignition filter paper		(-)	No	(-)	No
EN 13823 (6)	FIGRA <sub>0,2 MJ</sub> (W/s)		15	(-)	≤ 120	(-)
	FIGRA <sub>0,4 MJ</sub> (W/s)		(-)	(-)	(-)	(-)
	LFS <sub><edge< sub=""></edge<></sub>		(-)	Yes	(-)	Yes
	THR <sub>600s</sub> (MJ)		1,7	(-)	≤ 7,5	(-)
	SMOGRA (m²/s²)	2	8	(-)	≤ 180	(-)
	TSP <sub>600s</sub> (m <sup>2</sup> )	2	56	(-)	≤ 200	(-)
	Flaming					
	droplets/particles				-	
	f<10s		(-)	Yes	(-)	Yes
	f>10s		(-)	No	(-)	No

- (-) Not applicable
- (\*) The material did not melt nor pull away from the pilot burner.
- (5) Based on the results obtained in test report Nr. 12700C, "Digifort P300" red, design 2423
- (6) Based on the results obtained in test report Nr. 12700E, "Digifort P300" red, design 2423

### 3. CLASSIFICATION AND DIRECT FIELD OF APPLICATION

# a) Reference and direct field of application

This classification has been carried out in accordance with clause 10.6 of EN 13501-1: 2007 and prEN 15102: 2004.

#### b) Classification

The product "Digifort P300" in relation to its reaction to fire behavior is classified as:

Fire behavior	Smoke production	Flaming droplets
В	s2	d0

#### c) Field of application

This classification for the product as described in §1b, is valid for the following end use conditions:

- Glued on any backing with a fire performance of A2 or better with a density of equal to or greater than 870 kg/m³ and a thickness of equal to or greater than 11 mm.
- Without a void
- Fixing: glued with BK10-PVA adhesive (200g/m²)
- With joints

# Additional classification report Nr 13854A Page 5 of 5



This classification is valid for the following product parameters:

- Nominal mass per unit area: 300 g/m²
- All colours

### 4. RESTRICTIONS

At the time the standard EN 13501-1 (2007) was published, no decision was made concerning the duration of validity of a classification report.

#### WARNING

This classification report does not represent type approval nor certification of the product.

The following statement is included in accordance with Fire Sector Group Recommendation 001:

"The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of a system 3 attestation of conformity and CE marking under the Construction Products Directive.

The manufacturer has made a declaration, which is held on file. This confirms that the product's design requires no specific processes, procedures or stages (e.g. no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references to the manufacturer's factory production control that is aimed to be relevant to the samples tested and that will provide for their traceability."

Report	Name	Signature (*)	Date		
Prepared by	Ing. Frans DUTRIEUE	House	2 4 MAART 2009		
Reviewed by	Prof. Dr. Ir. Paul VANDEVELDE	4	2 4 MAART 2009		
(*) For and on behalf of "WFRGENT N.V."					

EN 13501-1 B-C-D WG 3E\*

The present report constitutes an addition to Test Report Nr 12700F dated 12/06/207. It has been drafted in accordance with the regulations of EGOLF regulation R4 "Application Note: clause 5.10 [5.10/4] – Issue 01 - 2001/03/12 – amendment of test reports: clients changing product / company names (II) – for commercial reasons". The product "Digifort P300" has not been retested. Present additional report does not contain any technical modifications to the original test report.

Both the original and the new denomination of the product and of the company entrusted with marketing the product will be documented and entered in the laboratory's archives.

This report may be used only literally and completely for publications. - For publications of certain texts, in which this report is mentioned, our permission must be obtained in advance.