

No.: GZIN1802007567CM

Date: Apr 10, 2018

Page: 1 of 8

CUSTOMER NAME:

S IGEPA group

Sample Name : Aluminum Composite Panel **B-bond**

Product Specification 2mm

Above information and sample(s) was/were submitted and confirmed by the client. SGS, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

Date of Receipt

Feb 09, 2018

Testing Start Date

Feb 09, 2018

Testing End Date

: Apr 10, 2018

Test result(s)

For further details, please refer to the following page(s)

(Unless otherwise stated the results shown in this test report refer only to

the sample(s) tested)

Signed for SGS-CSTC Standards Technical Services Co., Ltd. GZ Branch Testing Center

Salon Liu

Authorized signatory





No.: GZIN1802007567CM

Date: Apr 10, 2018

Page: 2 of 8

Test Result Summary

Test(s) Requested	Result(s)	
EN 13501-1:2007+A1:2009 Fire classification of construction products and	01	
building elements-Part 1: Classification using data from reaction to fire tests	Classification: C-s1, d0	
Summary:		
1. For further details, please refer to the following page(s).		



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service print overleaf, available on request or accessible at <a href="https://www.sas.com/en/ferma-and-Conditions.aspx.and-for-electronic Iorand document subject to Terms and Conditions for Electronic Documents at <a href="https://www.sas.com/en/ferms-and-Conditions/enrs--Document.sas-Attention is drawn to the iminitation of liability, indemnification and jurisdiction issues defined therain. Any holder of this document document advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits client is an expectation. The Company's acide responsibility is to list Client and this document does not exceed parties to transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduce except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or felsification of the content appearance of this document is unlawful and offenders may be prosecuted to the fulliast stient of the law. Unless otherwise stated tresults shown in this teatreport refer only to the sample(s) are retained for 30 days only.

Attention:To check the authenticity of testing / inspection report & certificate, please contact us at telephone (86-755) 83

1986 kath Road Scientech Part, Ezomoria Hohridal Developman District, Guarghou, China. 510683 t (86-20) 82155555 f (86-20) 82075080 www.sgegroup.com.cn 中国・广州・经济技术开发区科学域科珠路198号 邮稿: 510683 t (86-20) 82155555 f (86-20) 82075080 e sgs.china@sgs.com



No.: GZIN1802007567CM

Date: Apr 10, 2018

Page: 3 of 8

TESTS AND RESULTS

Test Conducted:

This test is conducted as per EN 13501-1:2007+A1:2009 Fire classification of construction products and building elements- Part 1: Classification using data from reaction to fire tests. And the test methods as following:

- 1. EN 13823:2010 Reaction to fire tests for building products Building products excluding floorings exposed to the thermal attack by a single burning item.
- 2. EN ISO 11925-2:2010+AC:2011 Reaction to fire tests-Ignitability of building products subjected to direct impingement of flame-Part 2: Single-flame source test.

Mounting and fixing (For EN 13823):

The specimen was tested free standing at a distance of at least 80 mm from the backing board. Both wings were clamped at the top and the bottom.

Test Results:

Test method	<u>Parameter</u>	Number of tests	Results	
	FIGRA _{0.4MJ} (W/s)		219.2	
EN 13823:2010+A1:2014	THR _{600s} (MJ)		10.6	
	SMOGRA (m²/s²)		3.2	
	TSP _{600s} (m ²)	3	19.6	
	LFS < edge of specimen		Yes	
	Flaming particles or		No	
	droplets		No	
EN ISO 11925-	<i>F</i> s ≤ 150 mm		Yes	
2:2010+AC:2011	Ignition of the filter paper	6	No	
Exposure = 30 s	ignition of the filter paper		NO	

Remark:

FIGRA-Fire growth rate index used for classification purposes [W/s]





No.: GZIN1802007567CM

Date: Apr 10, 2018

Page: 4 of 8

For the classes A2 and B, FIGRA_{0.2}MJ
For the classes C and D, FIGRA_{0.4}MJ
LFS-Lateral flame spread m
THR_{600s}-Total heat release within 600 s MJ
SMOGRA-Smoke growth rate [m²/s²]
TSP_{600s}-Total smoke production within 600 s

Classification and direct field of application:

This classification has been carried out in accordance with EN 13501-1:2007+A1:2009.

Classification:

Fire behaviour		Smoke p	roduction		Flaming droplets	
С	-	S	1	,	d	0

Remark:

The classes with their corresponding fire performance are given in annex A.

Reaction to fire classification is based on the 7-step scale of A1 to F, where A1 is good and F is bad

Statement:

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

Warning:

This classification report does not represent type approval or certification of the product.

The test laboratory has, therefore, play no part in sampling the product for the test, although it holds appropriate references to the manufacturer's factory production control that is aimed to be relevant to the samples tested and that will provide for their traceability.





No.: GZIN1802007567CM

Date: Apr 10, 2018

Page: 5 of 8

Table 1 — Classes of reaction to fire performance for construction products excluding floorings and linear pipe thermal insulation products.

Class	Test method(s) Classification criteria		Additional classification	
			<i>∆T</i> ≤30°C, and	
A1	EN ISO 1182 ^a	and	<i>∆m</i> ≤50%, and	-
			t _f =0(i.e. no sustained flaming)	
	EN ISO 1716		PCS≤2.0MJ/kg ^a and PCS≤2.0MJ/kg ^{bc} and PCS≤1.4MJ/m ^{2 d} and PCS≤2.0MJ/kg ^e	-
			<i>ΔT</i> ≤50°C, and	
A2	EN ISO 1182 ^a or	and	<i>∆m</i> ≤50%, and	-
			t _f ≤20 s	
	EN ISO 1716		PCS≤3.0MJ/kg ^a and PCS≤4.0MJ/m ^{2 b} and	-





No. : GZIN1802007567CM

Date: Apr 10, 2018

Page: 6 of 8

			PCS≤4.0MJ/m ^{2 d} and PCS≤3.0MJ/kg ^e	
	EN 13823		FIGRA≤120W/s and LFS <edge and<br="" of="" specimen="">THR_{600s}≤7.5MJ</edge>	Smoke production ^f and Flaming droplets/particles ^g
В	EN 13823	and	FIGRA≤120W/s and LFS <edge and<br="" of="" specimen="">THR600s≤7.5MJ</edge>	Smoke production f and Flaming droplets/particles g
	EN ISO 11925-2 Exposure =30s	2 i	Fs≤150mm within 60 s	
С	EN 13823	and	FIGRA≤250W/s and LFS <edge and="" of="" specimen="" td="" thr600s≤15mj<=""><td>Smoke production f and Flaming droplets/particles g</td></edge>	Smoke production f and Flaming droplets/particles g
	EN ISO 11925-2 Exposure=30s	i	Fs≤150mm within 60 s	
D	EN 13823	and	FIGRA≤750W/s	Smoke production f and Flaming droplets/particles g
	EN ISO 11925-2 Exposure=30s		Fs≤150mm within 60 s	
Е	EN ISO 11925-2 Exposure =15s	i	Fs≤150mm within 20 s	flaming droplets/particles h
F	No performance of	determine	d	

^a For homogeneous products and substantial components of non-homogeneous products.

^d For any internal non-substantial component of non-homogeneous products.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printer overlead, available on request or accessible at http://www.sas.com/inst/farms.and-Conditions.aspx and, for electronic format occuments and the first of the first of

198 Kazhu Road, Scheleich Park, Economic & Technical Development District, Guangthou, China. 510663 t (86-20) 82155555 f (86-20) 82075080 www.sgsgroup.com中国・广州・经济技术开发区科学域科荣路198号 解線: 510663 t (86-20) 82155555 f (86-20) 82075080 e sgs.china@sqs.c

^b For any external non-substantial component of non-homogeneous products.

 $^{^{\}circ}$ Alternatively, any external non-substantial component having a PCS \leq 2,0 MJ/m 2 , provided that the product satisfies the following criteria of EN 13823: FIGRA \leq 20 W/s, and LFS < edge of specimen, and THR $_{600s} \leq$ 4,0 MJ, and s1, and d0.



No.: GZIN1802007567CM

Date: Apr 10, 2018

Page: 7 of 8

^f In the last phase of the development of the test procedure, modifications of the smoke measurement system have been introduced, the effect of which needs further investigation. This may result in a modification of the limit values and/or parameters for the evaluation of the smoke production.

 $s1 = SMOGRA \leq 30m^2/s^2 \ and \ TSP_{600s} \leq 50m^2 \ ; \ s2 = SMOGRA \leq 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2 \ and \ TSP_{600s} \leq 200m^2; \ s3 = 180m^2/s^2$ = not s1 or s2

^g d0 = No flaming droplets/ particles in EN 13823 within 600 s;

d1 = no flaming droplets/ particles persisting longer than 10 s in EN 13823 within 600 s;

d2 = not d0 or d1.

Ignition of the paper in EN ISO 11925-2 results in a d2 classification.

^h Pass = no ignition of the paper (no classification);

Fail = ignition of the paper (d2 classification).

Under conditions of surface flame attack and, if appropriate to the end-use application of the product, edge flame attack.

SAMPLE INFORMATION AND PICTURES

Thickness: About 2mm

Mass per unit area: About 3.31kg/m²



^e For the product as a whole.



No.: GZIN1802007567CM

Date: Apr 10, 2018

Page: 8 of 8





Before Test (EN 13823)

After Test (EN 13823)

Note: The above test was carried out by SGS-CSTC Standards Technical Services Co., Ltd. Shunde Branch. ****** End of report******



198 Kezhu Road, Scienlech Park, Economic & Technical Development District, 中国 - 广州 - 经济技术开发区科学城科珠路198号

mani District, Guangghou, China. 510663 1 (86-20) 82155555 f (86-20) 82075080 www.sgsgroup.com.cn 器198号 鄭飾: 510663 1 (86-20) 82155555 f (86-20) 82075080 e sgs.china@sgs.com